

READ THIS FIRST

Both $\frac{1}{2}$ " and $\frac{3}{4}$ " connections are included with this Webstone valve set. See the chart below to determine which size to use.

$\frac{1}{2}$ "	$\frac{3}{4}$ "
AQ 125 B	AQ 250 SX
AQ 125 FX	AQ 250 SXO
AQ 125 HX	GWH-635-ES
GWH-425-HN	GWH-635-ESO
GWH-425-EF	

Replacing Union Connection

- Remove Union Assembly Nut
- Install proper sized Union Assembly Connector, ensuring gasket is installed. (See Fig 1) (Blue ring is for cold and red ring is for the hot valve)

Note: The hot valve has connector for the pressure relief valve (see Fig 2)

- See Webstone Valve instruction for further installation instructions.





Fig 2